

Event Services

Display Vehicle Requirements

Event name: _____

Event dates: _____

Vehicle location/booth #: _____

Vehicle make/model/year: _____

Vehicle owner/operator: _____

Owner cell phone #: _____

***Owner must be available by cell phone at all times when the vehicle is displayed in the venue.*

- Floor protection installed
- Electric Vehicle (the next four lines do not apply)
- Fuel tank less than ¼ tank or five gallons
- Battery cables disconnected and taped
- Fuel tank cap locked or taped
- Interior fuel latch disabled

Verified by SCC Staff: _____

Vehicles

- Displayed vehicles must be indicated on floor plans for Fire Marshal approval.
- Schedule for delivery and removal must be submitted to your EM.
- Fuel in tanks is limited to a maximum of ¼ tank or five gallons, whichever is less.
- Diesel fuel tanks are limited to a maximum of ¼ tank.
- Vehicles with no or non-functioning fuel gauges will not be allowed in public assembly areas without prior approval by the Fire Marshal.
- Battery cables must be disconnected, with the cable ends taped over to prevent sparking.
- Display vehicles with equipment to be operated must be connected to facility shore power provided by Edlen Electrical.
- Fuel tank fill caps must be either lockable or taped shut.
- Interior latch release, if so equipped, must be disabled.
- Visqueen must protect facility flooring.
- Vehicles may not be moved during event hours.
- Electric vehicles are exempted from these requirements. Hybrids with liquid fuel must comply as above.

Display in the vehicle for Seattle Fire Department's reference.